



AVK Series 24 Ductile Iron Wet Barrel Hydrants **UL/FM Certificate of Compliance**

This letter is to certify that the Series 24 ductile iron Wet Barrel Fire Hydrants manufactured by American AVK Company in Minden, Nevada, meet or exceed the standards established UL 246 and FM1511. The hydrants are listed with UL and are FM approved.

Each hydrant is tested, after assembly, to a static pressure of 400 psi. The AWWA, UL and FM working pressure is rated to 200 psi.

In addition, all American AVK fire hydrants have a 10 year limited warranty against manufacturing and material defects from the date of purchase.

If you have any questions or need further information, please feel free to contact us.

On behalf of American AVK,

A handwritten signature in black ink that reads "John Wilber". The signature is cursive and somewhat stylized.

John Wilber

VP Engineering
American AVK Company

American AVK Company

2155 Meridian Blvd
Minden, NV 89423

Tel: (775) 552-1400
Fax: (775) 552-1031

sales@avkus.com
www.americanavk.com

Expect... The AVK logo, consisting of the letters 'AVK' in a bold, blue, stylized font.